180008250711

中国认可
国际互认
检测
TESTING
CNAS L0699

CEPRI

TEST REPORT

CEPRI-EETC02-2023-0058(E)

Client： Xi ’an Tiangong Electric Co.,Ltd

Object： Metal Oxide Varistor

Type： Φ60mm×24mm

Test Category： Characteristics test

POWER INDUSTRY QUALITY INSPECTION AND TEST CENTER FOR ELECTRIC EQUIPMENT

NOTICE

1. This report will enter into effect with seals of test center.
2. This report is legally made available accompany with compiled, checked, verified and approved signatures.
3. Alter the report is invalid.
4. This report only takes responsibility to the test object.
5. Part of copy is invalid.
6. Any objections in the report should be posed within 15 days once the report is received.
7. The inspection and testing management system of China Electric Power Research Institute includes the following institutes:

National Wind Power Integration Research and Test Center

☆**Power Industry Quality Inspection and Test Center for Electric Equipment**

Power Industry Quality Inspection & Test Center for Electric Power Equipment and Instruments

Power Industry Quality Inspection & Test Center for Electrical Material and Components

Power Industry Quality Inspection & Test Center for Automation Equipment

Power Industry Quality Inspection & Test Center for Communication Equipment

Power Industry Quality Inspection & Test Center for Concrete Power and Communication Poles

Power System Electromagnetic Compatibility and Electromagnetic Environmental Research and Monitoring Center

Address: NO.143, Luoyu Road, Hongshan District, Wuhan, Hubei Province, 430074.

Fax： 86-27-5937-8488 Service line:86-27-59258069 Supervision hotline：86-10-82813498

E-mail： eetc@epri.sgcc.com.cn Website：http://www.epri.sgcc.com.cn

Catalogue

Test Report	Power Industry Quality Inspection and Test Center for Electric Equipment		CEPRI-EETC02-2023-0058(E) Total 12 Page 2
Client	Xi ’an Tiangong Electric Co.,Ltd	Manufacturer	Xi ’an Tiangong Electric Co.,Ltd
Object	Metal Oxide Varistor	Type	Φ60mm×24mm
Sampling procedure	By the client delivery	Serial No.	19 resistors (301～319)
Test Category	Characteristics test	Date	2023.02.13~2023.03.31
Requirements	1. GB/T 11032-2020 Metal-oxide surge arresters without gaps for a.c. systems 2.IEC 60099-4 Edition 3.0 (2014-06) Metal-oxide surge arresters without gaps for a.c. systems		
Conclusion	The metal oxide Varistor(Φ60mm×24mm)has passed the type test specified in GB/T 11032-2020 and IEC 60099-4 Edition 3.0 (2014-06).		
Note	Note :See appendix A for sample instruction.		

Tested by: 梁菊霞 　　陈立

Checked by: 王陆璐 　　**Verified by:** 左中秋

Approved by: 王保山 　　**Date of issue:** 2023-04-12

Test Results

No.	Item	Requirements		Results	Evaluation
1	Residual voltage test	Lightning impulse	≤8.69±0.5kV$_p$	8.60kV$_p$~8.69kV$_p$	Data only
		Switching impulse	Data only	See the text for details	
		Steep current impulse	Data only	See the text for details	
2	High current impulse withstand test	4/10μs、 100 kA 、2times		100.0kA～104.0kA	Pass
3	Repetitive charge transfer rating withstand test	Q_{rs} = 2C by 2ms rectangular current for 20 times.		2.224 C ~2.405C	Pass
4	Test to verify long term stability under continuous operating voltage	Charge ability 85%, 115℃,1000h.		P_{max}≤1.3P_{min}, $P_{all.max}$≤1.1P_{start}.	Pass

(No content in this page below)

Content:

1 Residual voltage test

1.1 Lightning impulse residual voltage test

Samples				301	302	303
Resistor	U_{3mAAC}	Measured value	kV	3.86	3.84	3.84
		Specified value	kV_p	⩾3.66		
	8/20μs, 5kA		kV_p	8.22	8.19	8.23
	8/20μs, 10kA		kV_p	8.69	8.60	8.62
	8/20μs, 20kA		kV_p	9.48	9.36	9.38
	Specified value		kV_p	⩽8.69±0.5		

Note 1：Shunt 0.025 V/A，divider K_d=206.8

Note 2：According to the determined residual pressure, draw the residual voltage and current curve, in the curve corresponding to the nominal discharge current read residual voltage, defined as the lightning protection lightning protection level.

1.2 Switching impulse residual voltage test

Samples			301	302	303
Resistor	U_{3mAAC}	kV	3.86	3.84	3.84
	Residual voltage at 500A	kV_p	7.16	7.11	7.11
	Residual voltage at 1000A	kV_p	7.28	7.24	7.28
	Residual voltage at 2000A	kV_p	7.69	7.65	7.65

Note：Shunt 0.025 V/A，divider K_d=206.8

1.3 Steep current impulse residual voltage test

Samples			301	302	303
Resistor	U_{3mAAC}	kV	3.86	3.84	3.84
	8/20μs, 10kA	kV_p	9.45	9.39	9.39

Note1：Shunt 0.0267 V/A, divider K_d=59.8。

Note 2： If U_{res2}/ U_{res1} is less than 2%, there is no need to correct Inductive effect.

Data only. Test waveform is shown in figure C.1 ~ figure C.3.

(No content in this page below)

2 High current impulse withstand test

Environment temperature：17.0℃ humidity: 53%

Samples		304	305	306	Specified value
U_{1mADC} （Positive +）	kV	5.13	5.07	5.08	/
U_{1mADC}（Negative -）	kV	5.12	5.09	5.09	/
8/20μs U_{10kAp} before	kV_p	8.54	8.52	8.51	/
1st impulse	kA	104.0	104.0	101.2	100kA，The interval should allow the samples to cool to ambient temperature
2nd impulse		100.0	101.2	100.0	
U_{1mADC} （Positive +）	kV	5.13	5.00	5.08	/
Change rate（Positive +）	%	0	-1.38	0	/
U_{1mADC}（Negative -）	kV	5.06	5.02	5.05	/
Change rate（Negative -）	%	-1.17	-1.38	-0.79	/
Visual inspection		No puncture, flashover or cracking.			No puncture, flashover or cracking.

Note：Shunt 0.001V/A。

Fulfilled the requirements. Test waveform is shown in figure C.4.

(No content in this page below)

3 Repetitive charge transfer rating withstand test

Environment temperature: 13.0℃ humidity:72%

Samples		310	311	312	313	314	315	316	317	318	319
Before test	U_{3mAAC}, kV	3.75	3.75	3.79	3.79	3.76	3.78	3.79	3.78	3.77	3.76
	8/20μsU_{10kA}, kV	8.16	8.17	8.24	8.29	8.23	8.24	8.26	8.25	8.24	8.23
Q_{rs}, C		Q_{rs} (Claimed repetitive charge transfer rating) ×1.1=2.2									
1st	Q_{rs}, C	2.253	2.376	2.405	2.295	2.369	2.381	2.405	2.251	2.257	2.334
2nd	Q_{rs}, C	2.271	2.345	2.357	2.244	2.355	2.336	2.357	2.233	2.225	2.314
3rd	Q_{rs}, C	2.315	2.385	2.404	2.306	2.378	2.371	2.404	2.262	2.251	2.349
4th	Q_{rs}, C	2.295	2.348	2.344	2.243	2.335	2.322	2.344	2.224	2.233	2.315
5th	Q_{rs}, C	2.244	2.353	2.342	2.257	2.334	2.303	2.342	2.235	2.262	2.367
6th	Q_{rs}, C	2.306	2.350	2.277	2.225	2.314	2.269	2.277	2.251	2.224	2.328
7th	Q_{rs}, C	2.243	2.356	2.358	2.251	2.349	2.336	2.244	2.385	2.357	2.355
8th	Q_{rs}, C	2.257	2.321	2.324	2.233	2.315	2.316	2.306	2.348	2.404	2.378
9th	Q_{rs}, C	2.225	2.352	2.368	2.262	2.367	2.308	2.243	2.353	2.344	2.335
10th	Q_{rs}, C	2.251	2.405	2.356	2.224	2.328	2.302	2.257	2.350	2.342	2.334
11th	Q_{rs}, C	2.233	2.357	2.334	2.295	2.369	2.381	2.225	2.356	2.277	2.314
12th	Q_{rs}, C	2.262	2.404	2.314	2.334	2.355	2.336	2.251	2.321	2.358	2.349
13th	Q_{rs}, C	2.224	2.344	2.349	2.314	2.378	2.371	2.233	2.364	2.324	2.315
14th	Q_{rs}, C	2.295	2.342	2.315	2.349	2.334	2.322	2.262	2.319	2.368	2.367
15th	Q_{rs}, C	2.334	2.277	2.367	2.315	2.314	2.303	2.224	2.385	2.339	2.328
16th	Q_{rs}, C	2.314	2.358	2.334	2.367	2.349	2.269	2.244	2.348	2.357	2.355
17th	Q_{rs}, C	2.349	2.324	2.314	2.328	2.315	2.336	2.306	2.353	2.304	2.378
18th	Q_{rs}, C	2.315	2.368	2.349	2.334	2.367	2.316	2.243	2.35	2.340	2.335
19th	Q_{rs}, C	2.367	2.335	2.315	2.314	2.328	2.308	2.257	2.356	2.342	2.334
20th	Q_{rs}, C	2.338	2.328	2.367	2.349	2.334	2.287	2.225	2.321	2.277	2.314
Test evaluation	U_{3mAAC}, kV	3.80	3.80	3.86	3.86	3.82	3.86	3.85	3.86	3.84	3.82
	Change rate, %	+1.33	+1.33	+1.85	+1.85	+1.60	+2.12	+1.58	+2.12	+1.86	+1.60
	8/20μs U_{10kA}, kV	8.21	8.28	8.32	8.34	8.32	8.31	8.32	8.34	8.32	8.30
	Change rate, %	+0.61	+1.35	+0.97	+0.60	+1.09	+0.85	+0.72	+1.09	+0.97	+0.85
	One 8/20 current impulse, kA	14.13kA (0.5kA/cm^2=0.5×3.14×(6.0/2)^2=14.13kA which is lower than 2 times I_n)									
		19.52	19.58	19.62	19.54	19.62	19.35	19.40	19.36	19.42	19.35
	Visual inspection	All the samples have no puncture, flashover or cracking.									

Note: Shunt 0.01V/A.

Fulfilled the requirements, the test waveforms were shown in fig C.5.

4 Test to verify long term stability under continuous operating voltage

Samples	307	308	309
U_{1mADC}, kV	5.15	5.20	5.18
U_{ct}, kV_{rms}	3.31	3.31	3.31
Charge rate,%	90.1	90.0	90.4
U_{3mAAC}, before test	3.75	3.78	3.79
U_{3mAAC},after test	3.97	3.98	3.95
Change rate, %	+5.34	+5.30	+4.23
Power losses P_{start}, 3h, W	2.404	2.111	2.864
Power losses P_{100h}, W	2.060	1.849	2.760
Power losses P_{200h}, W	1.989	1.817	2.196
Power losses P_{300h}, W	2.224	1.771	2.143
Power losses P_{400h}, W	1.979	1.959	2.060
Power losses P_{500h}, W	1.856	1.771	2.298
Power losses P_{600h}, W	2.064	1.681	2.046
Power losses P_{700h}, W	1.985	1.847	1.919
Power losses P_{800h}, W	2.072	1.777	2.128
Power losses P_{900h}, W	2.011	1.831	2.048
Power losses P_{end}, 1000+8h,W	2.090	1.782	2.136
P_{min}, W	1.846	1.681	1.919
Any increase of power losses from P_{min} during the remaining test period, P_{max}	2.090	1.847	2.136
$P_{all.max}$, W	2.404	2.111	2.864
P_{max} / $1.3P_{min}$	0.866	0.845	0.856
$P_{all.max}$ /1.1 P_{start}	0.909	0.909	0.909

Because $P_{max} \leqslant 1.3P_{min}$， $P_{all.max} \leqslant 1.1P_{start}$, the samples fulfilled the requirements.

Note：The temperature of blocks:115±4℃.

Fulfilled the requirements, the accelerated ageing curves were shown in fig 1.



Fig 1 The Accelerated ageing curve of samples

(No content in this page below)

Appendix A: Sample instruction

Sample instruction：

1） 19 resistors, number EETC02-23/01/20-0058-301~ EETC02-23/01/20-0058-319， short for 301~319 in report.

Appendix B: Main test device

NO.	Device name	Device NO.	Measurement	Uncertainty /Accuracy	Calibration institution	Expiration date
1	impulse current generator	EETC02-0003	8/20 μs 40 kA 4/10 μs 130 kA	U_{rel}=0.015 k=2	National center for high voltage measurement	2023-06-23
2	impulse current generator	EETC02-0005	8/20 μs 40 kA 30 kV 4/10 μs 2 kA 30 kV	U_{rel}=0.015 k=2 U_{rel}=0.018 k=2	National center for high voltage measurement	2023-06-29
3	Steep current impulse generator	EETC02-0004	8/20 μs 40 kA 30 kV 30/80 μs 2 kA 30 kV	U_{rel}=0.015 k=2 U_{rel}=0.018 k=2	National center for high voltage measurement	2023-06-29
4	DC reference voltage tester	EETC02-0049	DC 0~9 kV	U_{rel}=0.008 k=2	Hubei province meteorological metrological verification station	2023-07-12
5	Accelerated aging device for MO resistor	EETC02-0036	115℃	U_{rel} =0.3℃k=2	Hubei province meteorological metrological verification station	2023-08-03
			0~10kV	U_{rel}=0.013 k=2	National center for high voltage measurement	2024-03-08

(No content in this page below)

Appendix C The typical test waveform



Fig C.1 Lightning impulse current and residual voltage waveform (sample 301, shunt 0.025V/A, divider K_d=206.8)



Fig C.2 Switching impulse current and residual voltage waveform (sample 301, shunt 0.025V/A, divider K_d=206.8)



Fig C.3 Steep impulse current and residual voltage waveform (sample 301, shunt 0.0267V/A, divider K_d=59.8)



Fig C.4 Waveform of 304 conditioning test (first impulse)



Fig C.5 The 1st time of sample 310, Repetitive charge transfer withstand, 0.01V/A

(No content in this page below)

Appendix D: Photos of the arrester

Fig D1: Outside view of MO resistor (Φ60mm×24mm)